

GSH
Güteschutzgemeinschaft
Hartschaum e.V.

CERTIFICATE OF CONFORMITY

on the basis of EN 13172, Annex A

We herewith confirm that the building product

**Thermal insulating board
made of expanded Polystyrene**

- 1.) ISOPOR EPS 80 THP**
- 2 NEOCOAT EPS 80 THP**
- 3.) ISOPOR EPS 100 THP**

- 1 and 2.) EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – BS125 – CS(10)80 – TR150
- 3.) EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,-)1 – BS150 – CS(10)100 – TR150

- 1.) Euroclass E, declared thermal conductivity, $\lambda_D = 0,036 \text{ W/(m}\cdot\text{K)}$
- 2.) Euroclass E, declared thermal conductivity, $\lambda_D = 0,031 \text{ W/(m}\cdot\text{K)}$
- 3.) Euroclass E, declared thermal conductivity, $\lambda_D = 0,034 \text{ W/(m}\cdot\text{K)}$

1,2 and 3.) $W_{ip} \leq 0,5 \text{ kg/m}^2$, $f_{ik} \geq 0,02 \text{ N/mm}^2$, $G_m \geq 1,0 \text{ N/mm}^2$
(This specification covers the requirements for an EPS product applied in an ETICS,
according to ETAG 004 and EN 13499)

from the manufacturer


G. K. RIZAKOS SA
Lamia Industrial Estate
Lamia 35100, Greece

correspond to the technical specification of

EN 13163:2012+A1:2015

This certificate of conformity is valid until **31.12.2017**. The validity can be prolonged by seal of the GSH and signature of the manager of the certification body.

13.12.2016 / 15 11 740-R2.e


Manager of the Certification Body
Corth Siegfried

Prolonged until:

Prolonged until:



Schildenstraße 24
D-29221 Celle
Notified Body 0919
ÜZ: ÜG 049



Tel +49 (0)5141-88 92 65
Fax +49 (0)5141-88 92 67
www.gsh.eu
info@gsh.eu