

GSH
Güteschutzgemeinschaft
Hartschaum e.V.

ATTESTATION OF CONFORMITY

We herewith attest that the building products

Thermal Insulation Boards
made of expanded Polystyrene
NEOCOAT PLUS EPS 100 THP
NEOCOAT EPS 150 THP
NEOCOAT EPS 200 THP
NEOCOAT EPS 60 THP

with the designation code
described in Annex 1 (following page)

from the manufacturer

RIZAKOS S. A.
Lamia Industrial Estate
GR-35100 Lamia
GREECE

based on the Product Type Determination (former ITT) and the continuous surveillance and evaluation of the Factory Production Control, comply with the requirements of

EN 13163:2012+A1:2015.

The manufacturer RIZAKOS S.A. is authorized to bear the CE-mark on the above mentioned product. This attestation is valid until **31.01.2019**. The validity can be prolonged by seal of the GSH and signature of the manager of the certification body.

24.01.2018 / 15 11 058-R3.e



Manager of the Certification Body
Cortth Siegfried

prolonged until:

prolonged until:



Schildenstraße 24
D-29221 Celle
Notified Body 0919
ÜZ: ÜG 049

Tel +49 (0)5141-88 92 65
Fax +49 (0)5141-88 92 67
www.gsh.eu
info@gsh.eu

GSH Güteschutzgemeinschaft Hartschaum e.V.

Annex 1 of Attestation nr. 15 11 058-R3.e

Product description

NEOCOAT PLUS EPS 100 THP (HBCD free)

EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,90)1 – BS150 – CS(10)100 – TR100

Reaction to fire: Euroclass E, $W_{ip} \leq 0,5 \text{ kg/m}^2$ - $f_{ik} \geq 0,02 \text{ N/mm}^2$, $G_m \geq 1,0 \text{ N/mm}^2$

Declared Value of Thermal Conductivity $0,030 \text{ W/(m}\cdot\text{K)}$

(This specification covers the requirements for an EPS product applied in an ETICS,
according to ETAG 004 and EN 13499)

NEOCOAT EPS 150 THP (HBCD free)

EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,90)1 – BS200 – CS(10)150 – TR150

Reaction to fire: Euroclass E

Declared Value of Thermal Conductivity $0,030 \text{ W/(m}\cdot\text{K)}$

$W_{ip} \leq 0,5 \text{ kg/m}^2$, $f_{ik} \geq 0,02 \text{ N/mm}^2$, $G_m \geq 1,0 \text{ N/mm}^2$

(This specification covers the requirements for an EPS product applied in an ETICS,
according to ETAG 004 and EN 13499)

NEOCOAT EPS 200 THP (HBCD free)

EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,90)1 – BS250 – CS(10)200 – TR150

Reaction to fire: Euroclass E

Declared Value of Thermal Conductivity $0,030 \text{ W/(m}\cdot\text{K)}$

$W_{ip} \leq 0,5 \text{ kg/m}^2$, $f_{ik} \geq 0,02 \text{ N/mm}^2$, $G_m \geq 1,0 \text{ N/mm}^2$

(This specification covers the requirements for an EPS product applied in an ETICS,
according to ETAG 004 and EN 13499)

NEOCOAT EPS 60 THP (HBCD free)

EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,90)1 – BS100 – CS(10)60 – TR150

Reaction to fire: Euroclass E


Declared value of thermal conductivity: $0,032 \text{ W/(m}\cdot\text{K)}$

$W_{ip} \leq 0,5 \text{ kg/m}^2$, $f_{ik} \geq 0,02 \text{ N/mm}^2$, $G_m \geq 1,0 \text{ N/mm}^2$

(This specification covers the requirements for an EPS product applied in an ETICS,
according to ETAG 004 and EN 13499)

The manufacturer RIZAKOS S.A. is authorized to bear the CE-mark on the above mentioned product. This attestation is valid until **31.01.2019**. The validity can be prolonged by seal of the GSH and signature of the manager of the certification body.

24.01.2018 / 15 11 058-R3.e



Manager of the Certification Body
Corth Siegfried

prolonged until:

prolonged until:



Schildenstraße 24
D-29221 Celle
Notified Body 0919
ÜZ: ÜG 049

Tel +49 (0) 5141-88 92 65
Fax +49 (0) 5141-88 92 67
www.gsh.eu
info@gsh.eu